



Darrien- Noroton System 2014 Lead Compliance Testing Results

System is in Compliance

Rank	Collection Date	Lead Results (ppb)
1	06/12/14	None Detected
2	06/12/14	None Detected
3	06/12/14	None Detected
4	06/12/14	None Detected
5	06/12/14	None Detected
6	06/12/14	None Detected
7	06/12/14	None Detected
8	06/12/14	None Detected
9	06/12/14	None Detected
10	06/12/14	None Detected
11	06/12/14	None Detected
12	06/12/14	None Detected
13	06/17/14	None Detected
14	06/17/14	None Detected
15	06/17/14	None Detected
16	06/24/14	None Detected
17	06/25/14	None Detected
18	06/12/14	1
19	06/12/14	1
20	06/12/14	1
21	06/12/14	1
22	06/12/14	1
23	06/12/14	1
24	06/12/14	1
25	06/12/14	2
26	06/12/14	2
27	06/12/14	2
28	06/12/14	2
29	06/12/14	3
30	06/12/14	117

➤ 90th Percentile Result

PWS ID#: CT0350011