



**Simsbury System**  
**2016 Lead Compliance Testing Results**  
**System is in Compliance**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	08/16/16	None Detected
2	08/17/16	None Detected
3	08/18/16	None Detected
4	08/18/16	None Detected
5	08/18/16	None Detected
6	08/18/16	None Detected
7	08/18/16	None Detected
8	08/18/16	None Detected
9	08/19/16	None Detected
10	08/19/16	None Detected
11	08/19/16	None Detected
12	08/19/16	None Detected
13	08/19/16	None Detected
14	08/19/16	None Detected
15	08/19/16	None Detected
16	08/19/16	None Detected
17	08/19/16	None Detected
18	08/19/16	None Detected
19	08/19/16	None Detected
20	08/19/16	None Detected
21	08/24/16	None Detected
22	08/18/16	1
23	08/19/16	1
24	08/16/16	2
25	08/19/16	2
26	08/19/16	2
27	08/19/16	4
28	08/18/16	5
29	08/17/16	8
30	08/18/16	32

PWS ID#: CT1280021