

**Aquarion Water Company**  
**PFAS Sampling Results**

**Town/City: Danbury**

		All Results Reported as parts per trillion (ppt)						TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA			
Cedar Heights	Cedar Heights Wells, POE	2019	9	10	4	5	ND	28	70	ND
	Cedar Heights Wells, POE	Feb. 2020	11	11	4	5	ND	31	70	3
	Cedars Well, POE	2019	9	9	4	4	ND	26	70	ND
	Cedars Well, POE	Feb. 2020	12	10	3	5	ND	30	70	6
Hollandale Estates	Hollandale, Distribution Point	2019	4	ND	ND	ND	ND	4	70	ND
Indian Springs	Indian Springs Well, POE	2019	7	ND	3	ND	ND	10	70	ND
Ken Oaks	Ken Oaks Drive, Distribution Point	2019	3	ND	ND	ND	ND	3	70	ND
Pearce Manor	Pearce Manor, Distribution Point	2019	4	ND	ND	ND	ND	4	70	ND
Rolling Ridge	Rolling Ridge, Distribution Point	2019	4	ND	ND	ND	ND	4	70	ND

**Definitions:**

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer