

Aquarion Water Company
PFAS Sampling Results

Town/City: East Hampton

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
East Hampton	East Hampton Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.