

**Aquarion Water Company**  
**PFAS Sampling Results**

**Town/City: Lakeville / Salisbury**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL	Current	Other PFAS
								PFAS (5)	CT DPH	Tested
Lakeville	Pettee Street Wells, POE	2019	ND	ND	ND	ND	ND	ND	<b>70</b>	ND
	Salisbury Wells, POE	2019	3	ND	ND	ND	ND	3	<b>70</b>	ND
	Lakeville Reservoir, POE	2019	ND	ND	ND	ND	ND	ND	<b>70</b>	ND

**Definitions:**

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.