

**Aquarion Water Company
PFAS Sampling Results**

Town/City: Marlborough

All Results Reported as parts per trillion (ppt)

| Water System Name | Sample Location | Test Date | PFOA | PFOS | PFHpA | PFHxS | PFNA | TOTAL PFAS (5) | Current CT DPH Guideline | Other PFAS Tested PFBS |
|-------------------|----------------------|-----------|------|------|-------|-------|------|----------------|--------------------------|------------------------|
| Birchwood Estates | Birchwood Wells, POE | 2019 | ND | ND | ND | ND | ND | ND | 70 | ND |

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.