

**Aquarion Water Company  
PFAS Sampling Results**

**Town/City: Seymour / Oxford / Beacon Falls**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL	Current	Other PFAS
								PFAS (5)	CT DPH Guideline	Tested PFBS
Seymour	Oxford Wells 1+7, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
	Oxford Well 2, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
	Oxford Wells 5+6, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
	Maple Street, Distribution Point	2019	ND	ND	ND	ND	ND	ND	70	ND

**Definitions:**

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.