

Aquarion Water Company
PFAS Sampling Results

Town/City: Washington

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
Judea Depot	Depot Wells #1&3, POE	2019	3	5	ND	ND	ND	8	70	ND
Judea Green	Green Wells, POE	2019	ND	ND	ND	ND	ND	ND	70	ND
Quarry Ridge	Quarry Ridge Well, POE	2019	ND	ND	ND	ND	ND	ND	70	ND