

**Aquarion Water Company  
PFAS Sampling Results**

**Town/City: Woodbury**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA	TOTAL	Current	Other PFAS
								PFAS (5)	CT DPH Guideline	Tested PFBS
Woodbury	Woodbury Well 1, POE	2019	2	ND	ND	ND	ND	2	70	ND
	Woodbury Wells 2+3, POE	2019	4	7	ND	ND	ND	11	70	ND

**Definitions:**

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.