

**Aquarion Water Company of New Hampshire
PFAS Sampling Results**

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	PFOA Running Annual Average	PFOS	PFOS Running Annual Average	PFHxS	PFHxS Running Annual Average	PFNA	PFNA Running Annual Average	Other PFAS Tested				
										PFPeA	PFHxA	PFBA	PFBS	PFHpA
	NH DES MCL		12		15		18		11	NA	NA	NA	NA	NA
Mill Rd WTP	July 2019	6		ND		ND		ND		11	10	ND	ND	ND
	Dec. 2019	5		ND		ND		ND		NT	NT	NT	NT	NT
	Jan. 2020	14		5		2		ND		23	18	6	2	7
	May 2020	11		4		ND		ND		20	18	5	3	6
	July 2020	9	10	4	3	ND	1	ND	0	ND	13	ND	2	5
Well 5A	Nov. 2019	6		2		ND		ND		NT	NT	NT	NT	NT
	Feb. 2020	5		3		ND		ND		3	2	2	2	ND
	April 2020	4		4		ND		ND		ND	ND	ND	ND	ND
	July 2020	5	5	4	3	ND	0	ND	0	ND	3	ND	ND	ND
Little River WTP	Oct. 2019	5		3		ND		ND		NT	NT	NT	NT	NT
	Jan. 2020	4		3		ND		ND		3	2	2	3	ND
	April 2020	5		3		ND		ND		2	ND	ND	3	ND
	July 2020	3	4	ND	2	ND	0	ND	0	ND	ND	ND	ND	ND
Well 14	Oct. 2019	5		5		ND		ND		NT	NT	NT	NT	NT
	Nov. 2019	6		7		ND		ND		NT	NT	NT	NT	NT
	March 2020	6		4		ND		ND		5	5	ND	3	ND
	April 2020	6		6		ND		ND		6	5	2	3	2
	July 2020	2	5	ND	4	ND	0	ND	0	ND	ND	ND	ND	ND
Winnicut Rd WTP A (Wells 10,12,16,17)	Nov. 2019	2		ND		ND		ND		NT	NT	NT	NT	NT
	Feb. 2020	3		ND		ND		ND		ND	2	2	ND	ND
	April 2020	3		ND		ND		ND		ND	2	2	ND	ND
	July 2020	3	3	ND	0	ND	0	ND	0	ND	ND	ND	ND	ND
Winnicut Rd WTP B (Wells 10,12,16,18)	Oct. 2019	ND		ND		ND		ND		NT	NT	NT	NT	NT
	Jan. 2020	3		ND		ND		ND		2	2	2	ND	ND
	April 2020	3		ND		ND		ND		ND	2	ND	ND	ND
	July 2020	2	2	ND	0	ND	0	ND	0	ND	ND	ND	ND	ND
Winnicut Rd WTP C (Wells 10,12,13B,16, 19)	Oct. 2019	2		ND		ND		ND		NT	NT	NT	NT	NT
	March 2020	2		ND		ND		ND		ND	ND	ND	ND	ND
	April 2020	2		ND		ND		ND		ND	ND	ND	ND	ND
	July 2020	2	2	ND	0	ND	0	ND	0	ND	ND	ND	ND	ND

Footnote:

Compliance based on running annual average of last 4 quarters.

Definitions:

MCL - Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

ND - Not Detected

NT - Not Tested

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.

WTP - Water Treatment Plant