

Aquarion Water Company PFAS Sampling Results

Town/City: Darien

Water System Name: Darien

All Results Reported as parts per trillion (ppt)

Sample Location	Test Date	PFOA	CT DPH PFOA Action Level*	PFOS	CT DPH PFOS Action Level*	PFHxS	CT DPH PFHxS Action Level*	PFNA	CT DPH PFNA Action Level*
Post Road Station, Distribution Point	Aug. 2019	5		ND		ND		ND	
Springdale, Distribution Point	Aug. 2019	4		ND		ND		ND	
Rewak Well, POE [^]	Nov. 2020	13		10		4		ND	

Footnotes:

* Following the most recent toxicological studies, on 06/15/2022 CT DPH replaced the existing 70 ppt guideline with the chemical-specific levels included above. The action levels shown above apply only to samples collected on or after 06/15/2022.

[^] Rewak Well was taken offline from the distribution system after receiving results from the November 2020 sampling.

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.